



RFP 22MCO587

In response refer to RFP No. 22MCO587 Response to Follow Up Questions February 17, 2022

Gentlemen/Ladies:

The following questions have been asked, as a follow up to the Addendum 1 and Response to Question, and are hereby answered:

Cluster 1-2 Roads

1. Are the water mains that need to be lowered in the bid items Gardendale water or City of Midland water? This is important in regards to coordinating with the utility owners for the adjustments which is now stated in the sheet note.

Water mains are owned and operated by Greater Gardendale Water Supply Corporation. Dunaway has provided plans to Greater Gardendale Water Supply Corporation to begin the coordination effort to streamline the process for the contractor.

2. Is there any information on the size of the mains that will be lowered? This could drastically effect the price and availability for water lowering materials depending on the size and depth for 3ea locations, especially given current market volatility for these materials.

The size of the mains are anticipated to be 4" or 4-1/2". Additional information from Greater Gardendale Water Supply Corporation shall be shared as it becomes available.