



**RFP 22MCO599**

**In response refer to RFP NO22MCO599 Addendum 2 and Response to Additional Questions**

**December 8, 2022**

Gentlemen/Ladies:

This addendum is being issued to include revised drawing sheets as well as an updated bid tab.

The following additional question has been asked and is hereby answered:

1. What thickness is the concrete riprap that is in lieu of the Rock Riprap? Is there a Detail of the Toe?

**Concrete riprap in lieu of Rock Riprap shall be 5" thick. The detail of the Toe is included on Revised Sheet 9.**